


Optical Specification	
Model	OPT-CH03-110-F32
Optical Configuration	Bi-Telecentric
Working Distance (mm)	110±2
Magnification	0.3X
Sensor Ø(mm)	11.0(2/3")
Aperture	F32
Telecentricity	0.10°
NA	0.00469
Distortion	<0.1%
Depth of Field (mm)	29.34
Object Resolution (μm)	71.54
Resolution (μm)	15.6
Image MTF30(lp/mm)	32
Field of View Ø(mm)	36.67
O/I Distance (mm)	260.8
Mount	C-Mount
Weight (kg)	0.26
Size (mm)	Ø52.0×133.3
Filter Thread (mm)	M49×0.5-6H
Working temperature	-20℃~+60℃

- [1]Resolution:The resolution is the image resolution.
[2]WD:The distance between the front end of the mechanism and the object.
[3]DOF evaluation formula for telecentric lenses:

DOF(mm)= $\frac{F\# \times P \times k}{\beta \times \beta}$

F#:The real F-number of a lens when used
P:Sensor pixel size(5.5 μm used here)
β:Lens magnification
k:The parameter based on application (measurement, k=0.015;defect detection, k=0.008;0.015 used here)
At the borders of DOF,the image can still be used for measurement. But only half of the nominal DOF should be used to get a sharp image.



View Angle		Item	Signature	Date	OPT Machine Vision Tech Co., Ltd.			
		Drawing						
Standard Difference	IT14	Design			All Rights Reserved			
		Check						
Drawing Code		Scale			Name	OPT-CH03-110-F32		
		Paper Size	A4		Unit	mm	Page 1 / 1	Version 1.0