

A

B

C

D

Optical Specification

Model	OPT-CH20-110C-F32
Optical Configuration	Bi-Telecentric
Working Distance (mm)	110±2
Magnification	2.0X
Sensor Ø(mm)	11.0(2/3")
Aperture	F32
Telecentricity	0.10°
NA	0.03122
Distortion	<0.1%
Depth of Field (mm)	0.66
Object Resolution (μm)	10.75
Resolution (μm)	15.6
Image MTF30(lp/mm)	32
Field of View Ø(mm)	5.50
O/I Distance (mm)	257.1
Mount	C-Mount
Weight (kg)	0.17
Size (mm)	Ø29.0×129.58
Filter Thread (mm)	M27×0.5-6H
Working temperature	-20°C~+60°C

[1]Resolution:The resolution is the image resolution.

[2]WD:The distance between the front end of the mechanism and the object.

[3]DOF evaluation formula for telecentric lenses:

$$\text{DOF(mm)} = \frac{F\# \times P \times k}{\beta \times \beta}$$

F#:The real F-number of a lens when used


P:Sensor pixel size(5.5 μm used here)

β:Lens magnification


k:The parameter based on application (measurement,

k=0.015;defect detection, k=0.008;0.015 used here)

At the borders of DOF,the image can still be used for measurement. But only half of the nominal DOF should be used to get a sharp image.



View Angle



Item

Signature

Date



OPT Machine Vision Tech Co., Ltd.

Standard Difference

IT14

Drawing

Design

Check

All Rights Reserved

Drawing Code

Scale

Paper Size

A4

Name

Unit

mm

Page 1 / 1

Version

1.0

A

B

C

D